

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7125-1501:111 Page 1 of 1

CATEGORY: Fire Alarm Devices for the Hearing Impaired

LISTEE: *Edwards Signaling, 90 Fieldstone Court, Cheshire, CT 06410
Contact: David Mazur (203) 699-3000 Fax (203) 699-3100

DESIGN: Models 2457CS-15-R, 2457CS-15-W, 2457CS-15/75-R, 2457CS-15/75-W, 2457CS-30-R, 2457CS-30-W, 2457CS-110R and 2457CS-110-W chime/strobes. Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: Candela: -15: 15cd
-30: 30cd
-15/75: 15/75cd
-110: 110cd

Electrical: 20-24 VDC

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, candela/electrical rating and UL label.

APPROVAL: Listed as chime/strobes for use with separately listed compatible control units. Suitable for the hearing impaired applications and for indoor use only.

If this appliance is required to produce a distinctive three-pulse Temporal Pattern Fire Alarm Evacuation Signal (for total evacuation) in accordance with NFPA 72, 1999 Edition, the appliance must be used with a fire alarm control unit that can generate the temporal pattern signal. Refer to manufacturer's Installation Manual for details.

XLF: 7125-1388:202

*Rev. 06-17-2003



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

JUNE 17, 2003

*Listing Expires **June 30, 2004***

Authorized By:

DIANE K. AREND, Senior Deputy
Program Manager